

# 3rd International PFAS Congress

Paris  
June 6th, 2024

## Performance of Reverse Osmosis for the treatment of hazardous wastewater containing various concentrations and types of PFAS

*Manon Granger-Delacroix<sup>1</sup>, Elisabeth Geldof<sup>1</sup>, Sébastien Georges<sup>1</sup>, Nicolas Humez<sup>1</sup> and Julien Blanvillain<sup>2</sup>*

<sup>1</sup>SARPI-VEOLIA, Innovation and Processes Department, 427, route du Hazay, 78520 Limay, FRANCE.

<sup>2</sup>SEMEO, 22, Zone industrielle Le Relais, 35370 Bréal-sous-Vitré, FRANCE

SARPI  VEOLIA

# NOTICE - Disclaimer

The information contained in this statement is based on the Veolia group's understanding and know-how of the scientific and technical fields discussed herein as of the time of publication. Statements that may be interpreted as predictive of future outcomes or performance should not be considered guarantees of such, but rather reasoned assessments of the possible evolution of the technologies described.

As this document is based on the state of the Veolia group's scientific, technical, and regulatory knowledge at the time of its publication, the completeness and accuracy of the information contained herein cannot be guaranteed.

Descriptions contained herein apply exclusively to those examples and/or to the general situations specifically referenced, and in no event should be considered to apply to specific scenarios without prior review and validation.

# SARPI : a leading company in Europe

Treatment & valorization of  
hazardous waste

10 states in Europe

+ than 110 industrials sites


+ than 10 MT treated / year




SARPI  VEOLIA

# High variety of wastewaters

## High variety of origins



## High variety of matrices and pollutants



Challenge for the treatment of emergent pollutants by conventional technologies

Case of **PFAS**


# Technologies for PFAS retention

Conventional wastewater treatment technologies are insufficient in effectively treating short-chain PFAS




|                                     | Activated carbon | IE Resin | NF  | RO   |
|-------------------------------------|------------------|----------|-----|------|
| <b>Organic pollutants</b> reduction | ++               | +        | +++ | ++++ |
| <b>Long-chain PFAS</b> reduction    | ++               | ++       | +   | ++++ |
| <b>Short-chain PFAS</b> reduction   | -                | -        | -   | ++++ |
| <b>Monovalent ions</b> reduction    | -                | +        | -   | +    |
| <b>Polyvalent ions</b> reduction    | -                | +        | ++  | +++  |
| <b>Metal load</b> reduction         | +                | +        | -   | ++   |

# Reverse Osmosis technology



Driving force :

Pressure gradient = TransMembrane Pressure



Reference : Simpec

$$\text{Retention } a_j = \left( 1 - \frac{[a_j]_p}{[a_j]_c} \right) \times 100$$


$[a_j]_p$  concentration of molecule  $a_j$  in permeate ( $\text{ng}\cdot\text{L}^{-1}$ )  
 $[a_j]_c$  concentration of molecule  $a_j$  in concentrate ( $\text{ng}\cdot\text{L}^{-1}$ )

$$\text{Recovery} = \frac{Q_p}{Q_f} \times 100$$

$Q_p$  flow rate of permeate ( $\text{L}\cdot\text{h}^{-1}$ )  
 $Q_f$  flow rate of feed solution ( $\text{L}\cdot\text{h}^{-1}$ )

**Can we run RO with a high recovery rate to remove PFAS from pretreated hazardous wastewaters ?**

# Strategy



## Objective :

To maximize the global recovery rate during RO

# Material & methods


Mobile processing unit  
designed by **SEMEO**



**47** polymeric  
spiral-wound membranes  
for RO

2 or 3 stages  
Feed-and-bleed mode

$6.8 \pm 0.2 \text{ m}^3 \cdot \text{h}^{-1}$  of feed flow rate  
Ambiente temperature



## Analysis

Total organic carbon  
*internal lab*

Conductivity  
*internal lab*

30 PFAS  
*external lab*



# Composition of feed solutions

## Low-organic load


TOC

280 mg·L<sup>-1</sup>

Conductivity

10 202 μS·cm<sup>-1</sup>

Total PFAS

20 560 ng·L<sup>-1</sup>

## High-organic load


TOC

1 157 mg·L<sup>-1</sup>

Conductivity

10 189 μS·cm<sup>-1</sup>

Total PFAS

20 810 ng·L<sup>-1</sup>

# Hydraulic performances

## Low-organic load

**7.0 m<sup>3</sup>·h<sup>-1</sup>**  
feed solution  
flow rate

**32.1 bar**  
transmembrane pressure  
at 1st stage

**6.5 m<sup>3</sup>·h<sup>-1</sup>**  
1<sup>st</sup> stage  
permeate  
flow rate

**93 %**  
recovery at 1<sup>st</sup> stage

**6.2 m<sup>3</sup>·h<sup>-1</sup>**  
2<sup>nd</sup> stage  
permeate  
flow rate

**95 %**  
recovery at 2<sup>nd</sup> stage

**6.1 m<sup>3</sup>·h<sup>-1</sup>**  
3<sup>rd</sup> stage  
permeate  
flow rate

**98 %**  
recovery at 3<sup>rd</sup> stage

**87 % of  
Global  
Recovery**

## High-organic load

**6.6 m<sup>3</sup>·h<sup>-1</sup>**  
feed solution  
flow rate

**35.4 bar**  
transmembrane pressure  
at 1st stage

**5.8 m<sup>3</sup>·h<sup>-1</sup>**  
1<sup>st</sup> stage  
permeate  
flow rate

**88 %**  
recovery at 1<sup>st</sup> stage

**5.7 m<sup>3</sup>·h<sup>-1</sup>**  
2<sup>nd</sup> stage  
permeate  
flow rate

**98 %**  
recovery at 2<sup>nd</sup> stage





**86 % of  
Global  
Recovery**

$$Recovery = \frac{Q_p}{Q_f} \times 100$$





$Q_p$  flow rate of permeate (L·h<sup>-1</sup>)  
 $Q_f$  flow rate of feed solution (L·h<sup>-1</sup>)

# Quality of the permeates

## Low-organic load



## High-organic load



# Quality of the permeates

## Low-organic load


|              | Feed Solution<br>ng·L <sup>-1</sup> | Permeate Stage 1<br>ng·L <sup>-1</sup> | Permeate Stage 2<br>ng·L <sup>-1</sup> |
|--------------|-------------------------------------|--|--|
| 6:2 FTS      | 11 000                              | 450                                    | < 20                                   |
| PFHxA        | 3 400                               | 130                                    | < 20                                   |
| PFBA         | 1 800                               | 66                                     | < 20                                   |
| PFPeA        | 1 800                               | 66                                     | < 20                                   |
| PFHpA        | 1 400                               | 57                                     | < 20                                   |
| PFHxS        | 420                                 | 22                                     | < 20                                   |
| PFOS         | 270                                 | < 20                                   | < 20                                   |
| PFOA         | 185                                 | < 20                                   | < 20                                   |
| PFBS         | 140                                 | < 20                                   | < 20                                   |
| PFPeS        | 120                                 | < 20                                   | < 20                                   |
| 8:2 FTS      | 25                                  | < 20                                   | < 20                                   |
| <b>Total</b> | <b>20 560</b>                       | <b>791</b>                             | <b>&lt; LOQ</b>                        |

## High-organic load

|              | Feed Solution<br>ng·L <sup>-1</sup> | Permeate Stage 1<br>ng·L <sup>-1</sup> | Permeate Stage 2<br>ng·L <sup>-1</sup> |
|--------------|-------------------------------------|--|--|
| 6:2 FTS      | 15 000                              | 180                                    | < 20                                   |
| PFHxA        | 2 600                               | 34                                     | < 20                                   |
| PFBA         | 1 500                               | < 20                                   | < 20                                   |
| PFPeA        | 1 000                               | < 20                                   | < 20                                   |
| PFHpA        | 200                                 | < 20                                   | < 20                                   |
| PFOS         | 56                                  | < 20                                   | < 20                                   |
| PFOA         | 93                                  | < 20                                   | < 20                                   |
| 6:2 FTOH     | 361                                 | < 10                                   | n.d                                    |
| <b>Total</b> | <b>20 810</b>                       | <b>214</b>                             | <b>&lt; LOQ</b>                        |

# PFAS retention

## Low-organic load



$$\text{Retention } a_j = \left( 1 - \frac{[a]_p}{[a]_c} \right) \times 100$$


$[a]_p$  concentration of  $a_i$  in permeate (ng·L<sup>-1</sup>)  
 $[a]_c$  concentration of  $a_i$  in concentrate (ng·L<sup>-1</sup>)

## Retention (%)

|              | Stage 1          | Stage 2          |
|--------------|------------------|------------------|
| 6:2 FTS      | 99.5             | > 99.9           |
| PFHxA        | 99.5             | > 99.9           |
| PFBA         | 99.1             | > 99.7           |
| PFPeA        | 98.6             | > 99.6           |
| PFHpA        | 99.6             | > 99.8           |
| PFHxS        | 99.3             | > 99.4           |
| PFOS         | > 98.2           | > 98.2           |
| PFOA         | > 98.7           | > 98.7           |
| PFBS         | > 98.2           | > 98.2           |
| PFPeS        | > 97.6           | > 97.6           |
| 8:2 FTS      | > 88.2           | > 88.2           |
| <b>Total</b> | <b>&gt; 99.4</b> | <b>&gt; 99.9</b> |

# PFAS retention

## High-organic load



## Retention (%)

|              | Stage 1          | Stage 2          |
|--------------|------------------|------------------|
| 6:2 FTS      | 99.7             | > 99.9           |
| PFHxA        | 99.8             | > 99.9           |
| PFBA         | > 99.8           | > 99.8           |
| PFPeA        | > 99.1           | > 99.1           |
| PFHpA        | > 98.7           | > 98.7           |
| PFOS         | > 78.5           | > 78.5           |
| PFOA         | > 85.7           | > 85.7           |
| 6:2 FTOH     | > 99.3           | > 99.3           |
| <b>Total</b> | <b>&gt; 97.7</b> | <b>&gt; 99.9</b> |

$$\text{Retention } a_j = \left(1 - \frac{[a_j]_p}{[a_j]_c}\right) \times 100$$

$[a_j]_p$  concentration of  $a_j$  in permeate (ng·L<sup>-1</sup>)  
 $[a_j]_c$  concentration of  $a_j$  in concentrate (ng·L<sup>-1</sup>)

# Quality of the permeates

## Metals ( $\mu\text{g}\cdot\text{L}^{-1}$ )

|    | NF   | RO  |
|----|------|-----|
| Mn | 200  | < 5 |
| Cu | 6.1  | < 5 |
| Al | 31   | 6.3 |
| Fe | 68   | 19  |
| Zn | 34.5 | 7.8 |

## Volatile compounds ( $\mu\text{g}\cdot\text{L}^{-1}$ )

|                 | NF | RO  |
|-----------------|----|-----|
| $\text{CHCl}_3$ | 21 | < 1 |
| Xylène          | 3  | < 1 |

## Micropollutants ( $\mu\text{g}\cdot\text{L}^{-1}$ )

|                   | NF    | RO      |
|-------------------|-------|---------|
| C5-C9             | 82    | < 25    |
| AMPA              | 1.2   | < 0.1   |
| Phenol            | 0.01  | < 0.01  |
| Diuron            | 0.258 | < 0.05  |
| Atrazine          | 0.359 | < 0.025 |
| Isoproturon       | 0.146 | < 0.05  |
| Glyphosate        | 1.1   | < 0.1   |
| Tributylphosphate | 0.1   | < 0.1   |

# Take-away messages

**Reverse Osmosis with a high recovery rate can be run to efficiently remove PFAS from hazardous wastewaters**

## Hydraulic performances

A Global Recovery up to 87 % was successfully applied on pretreated wastewater

Wastewater with a  $10\text{mS}\cdot\text{cm}^{-1}$ -conductivity and a total organic carbon concentration of  $1100\text{ mg}\cdot\text{L}^{-1}$  could be treated by RO

The concentrates were able to be further treated

## Quality of the permeates

Both short-chain and long-chain PFAS were successfully treated

Total PFAS concentration below the limit of quantification was obtained after 2 stages of RO

In addition of PFAS, a wide range of organic micropollutants were removed

Inorganic pollutants concentration were reduced



**Merci pour votre  
attention.**

**Thanks for your  
attention.**

**SARPI**  **VEOLIA**